

CERTIFICATE OF COMPLIANCE

Certificate Number 20180828-S1871
Report Reference S1871-20121210
Issue Date 2018-AUGUST-28

Issued to: Bosch Security Systems Inc
130 Perinton Pkwy
Fairport NY 14450-9107

**This is to certify that
representative samples of**

CONTROL UNITS AND ACCESSORIES, HOUSEHOLD
SYSTEM TYPE; ACCESS CONTROL SYSTEM UNITS ;
CENTRAL-STATION ALARM UNITS; CONTROL PANELS,
SIA FALSE ALARM REDUCTION; HOLDUP ALARM
UNITS; LOCAL ALARM UNITS; POLICE-STATION-
CONNECTED ALARM UNITS; PROPRIETARY ALARM
UNITS; CENTRAL-STATION FIRE ALARM SYSTEM
UNITS CERTIFIED FOR CANADA; HOUSEHOLD
BURGLAR ALARM SYSTEM UNITS; CONTROL UNIT
ACCESSORIES, SYSTEM

See Next Page


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Next Page

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180828-S1871
Report Reference S1871-20121210
Issue Date 2018-AUGUST-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL: Fire Alarm and Security Equipment:
Models B3512, B4512 and B5512 Combination Residential Fire and Residential/Commercial Burglary Control Panels

ULC: Fire Alarm Equipment: Models B3512, B4512, B5512, and B6512 subscribers' units.

USL3, CNL: Fire Alarm and Security Equipment:
Models B6512 Combination Fire and Burglary Control Panels

USL, CNL: Fire Alarm and Security Accessories:
Models B915, B915I, B920, B930, B942, and B942W keypads, B56 Keypad Surface Mount Box

USL2, CNL2: Fire Alarm and Security Accessories:
Model B921C, B921CW keypad

ULC: Fire Alarm Accessories: Models B915, B915I, B920 keypads

USL, CNL: Fire Alarm and Security Subassemblies:
* Model B201 Zone Module,


USL: Fire Alarm and Security Subassemblies: Model B430 Phone Module, Models B440, B441, B442, B443, B444 Cellular Module,

ULC: Fire Alarm Subassemblies: Models B430 Phone Module, B442 and B443 Cellular Modules, D135A Low Battery Disconnect Module

Standard(s) for Safety

USL: The products have been investigated to, and found to be in compliance with the:

- UL 365 - Police Station Connected Burglar Alarm Units and Systems
- UL 609 - Local Burglar Alarm Units and Systems
- UL 636 - Holdup Alarm Units and Systems
- UL 1076 - Proprietary Burglar Alarm Units and Systems
- UL 1610 - Central-Station Burglar Alarm Units
- UL 1023 - Household Burglar Alarm System Units
- UL 1635 - Digital Alarm Communicator System Units
- UL 985 - Household Fire Warning System Units
- CP-01-2010 - Control Panel Standard - Features for False Alarm Reduction



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180828-S1871
Report Reference S1871-20121210
Issue Date 2018-AUGUST-28

USL2: The products have been investigated to, and found to be in compliance with the:

- UL 365 - Police Station Connected Burglar Alarm Units and Systems
- UL 609 - Local Burglar Alarm Units and Systems
- UL 1076 - Proprietary Burglar Alarm Units and Systems
- UL 1610 - Central-Station Burglar Alarm Units
- UL 1023 – Household Burglar Alarm System Units
- UL 1635 - Digital Alarm Communicator System Units
- UL 985 – Household Fire Warning System Units
- CP-01-2010 - Control Panel Standard - Features for False Alarm Reduction

CNL: The products have been investigated to, and found to be in compliance with the:

- ULC ORD C1023 - Household Burglar-Alarm System Units
- ULC ORD C1076 - Proprietary Burglar Alarm Units and Systems
- ULC S303 - Local Burglar Alarm Units and Systems
- ULC S304 - Central-Station Burglar Alarm Units
- ULC S545 - Residential Fire Warning System Control Units

CNL2: The products have been investigated to, and found to be in compliance with the:

- ULC ORD C1076 - Proprietary Burglar Alarm Units and Systems
- ULC S545 - Residential Fire Warning System Control Units

USL3: The products have been investigated to, and found to be in compliance with the:


- UL 365 - Police Station Connected Burglar Alarm Units and Systems
- UL 609 - Local Burglar Alarm Units and Systems
- UL 636 - Holdup Alarm Units and Systems
- UL 1076 - Proprietary Burglar Alarm Units and Systems
- UL 1610 - Central-Station Burglar Alarm Units
- UL 1023 – Household Burglar Alarm System Units
- UL 1635 - Digital Alarm Communicator System Units
- UL 985 – Household Fire Warning System Units
- CP-01-2010 - Control Panel Standard - Features for False Alarm Reduction
 - UL 294 - Access Control System Units

USL: The products (Models B430, B440, B441, B442, B443, B444) have also been investigated to, and found to be in compliance with the:

UL 864 – Control Units and Accessories for Fire Alarm Systems.

ULC: The products have also been investigated to, and found to be in compliance with the:

ULC-S559 – Equipment for Fire Signal Receiving Centres and Systems.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

